

City of Leavenworth
Public Works Department
Request for Bids
Asphalt Paving Repair Work
Bid Addendum 1

Bidder Question:

Would the City entertain the use of Chip Seal for the specified asphalt repair work?

City Response:

The City will allow an alternate bid for the use of Chip Seal for Schedule A and Schedule B as per the specifications provided in Addendum 1. Schedule C (TIB work) must remain asphalt replacement as outlined in the original bid specifications. Bids for asphalt installation of all Schedules (A, B & C) will be accepted with acknowledgement of the addendum and submittal of all revised bid forms provided in Addendum 1.

Items Included in Addendum 1:

1. Addendum 1 Request
2. Schedule A (Non TIB) Alternative Bid Addendum 1
3. Schedule B (Non TIB) Alternative Bid Addendum 1
4. Chip Seal Required Specifications
5. Revised Proposal Form Bid Summary Including Addendum 1
6. Revised Bidder Checklist

SCHEDULE B (Non TIB) ALTERNATE BID ADDENDUM 1 - TYPE 2 ASPHALT REPAIR - CHIP SEAL AS PER SPECIFICATION

ID	Site Address	Description	Approx. Sq. Ft.	Lump Sum Price \$
11	Center Street @ Ski Hill	Prep & Chip Seal as per Specification	1103 sq. ft.	
12	Cherry Street @ W. Center	Prep & Chip Seal as per Specification	900 sq. ft.	
13	Orchard Street at Pine	Prep & Chip Seal as per Specification	1440 sq. ft.	
14	424 Orchard Street	Prep & Chip Seal as per Specification	800 sq. ft.	
15	10th Street @ Commercial Street	Prep & Chip Seal as per Specification	4230 sq. ft.	
16	14th Street @ Front Street	Prep & Chip Seal as per Specification	2570 sq. ft.	
TOTALS		Prep & Chip Seal as per Specification	11043 ft. ²	

City of Leavenworth
Addendum 1
Chip Seal Specifications

General:

- Cutting of asphalt is not required.
- Subgrade replacement is not required.
- Site level areas as marked and as additionally required providing a smooth transition for the Chip Seal application.
- Apply to provide a clean, smooth transition to surrounding pavement.
- Uniform Application of Asphalt Emulsion and Aggregate as follows :

COAT	ASPHALT EMULSION (gal./sq.yd.)	AGGREGATE SIZE	AGGREGATE APPLIED (lbs./sq. yd.)
1	CRS2 @ .5 gal./sq. yd.	1/2" – 1/4 "	40 lbs./sq. yd.
2	CRS2 @ .65 gal./sq. yd.	3/8" – #10	30 lbs./sq. yd.

- Roll each layer with a Steel Drum roller and a Pneumatic roller or combination
- Caution flag the area treated for loose gravel.
- Sweep rocks after 1 week.

City of Leavenworth
Revised Proposal Form Including Addendum 1
Asphalt Street Repair Bid Summary

Contractor	Contractors Registration No. & Expiration Date
Street Address	Federal Tax I.D. No. or Social Security No.
City, State, Zip	L&I Account Number
Phone/Email	Unified Business Identity Number

	<u>ASPHALT</u>	<u>CHIP SEAL</u> (Addendum 1)
Schedule A - Type 1 Repair Total All Sites Lump Sum	\$ _____	\$ _____
Schedule B - Type 2 Repair Total All Sites Lump Sum	\$ _____	\$ _____
Schedule C - TIB Type 2 Repair Total All Sites Lump Sum	\$ _____	N/A
Total Bid Amount (Type 1 and Type 2)	\$ _____	\$ _____ (Total Includes Schedule C)

Signature below verifies acknowledgement of Bid Addendum 1.

Signature of Bidder	Date
---------------------	------

Printed Name

Title

REVISED BIDDER'S CHECKLIST

The Bidder's attention is called to the following forms which must be completed in full as required and submitted collectively as the Bid Proposal package:

- **Statement of Bidder's Qualifications**
- **Non-Collusion Certificate**
- **Schedule A Pricing Summary**
- **Schedule A - Alternate Bid Addendum 1 Pricing Summary**
- **Schedule B Pricing Summary**
- **Schedule B - Alternate Bid Addendum 1 Pricing Summary**
- **Schedule C Pricing Summary**
- **Revised Proposal Form Bid Summary Including Addendum 1**

The following forms are to be executed and submitted within 10 calendar days of award of contract:

- **Signed Contract**
- **Performance and Payment Bond**
- **Certificate of Insurance**
- **Statement of Intent to Pay Prevailing Wage**
- **Proposed Schedule of Work**