



Ref: Leavenworth Alpine Coaster

Soil compaction statement

To whom it may concern,

For the installation of the above reference ride in Leavenworth, Washington the following ground compaction specification are required:

Ground compaction under concrete footings shall be no less than: 130 kN/m² – 2,715 psf

Ground compaction under standard A-frame structure shall be no less than: 150kN/m² –3,130 psf

The ground compaction shall be tested and recorded according to the local building regulations and shall be made available for review during the final inspection of the Alpine Coaster.

Best regards.

.....
Engineer
Wiegand Sports USA.