

City of Leavenworth Request for Proposals
Purchase of Advanced Metering Infrastructure (AMI) System
Bid Addendum #2

Request:

Contractor concerns regarding set up/binding/programing problems with City involvement in lid cuts.

Decision:

Contractors will provide a Lid Cut Price per lid to be included in the bid packet.

LID CUT PRICE/LID = \$ _____

Acknowledgement Addendum #2 and Lid Cut Price (include in Bid Packet):

Name: _____

Title: _____

Date: _____

City of Leavenworth Request for Proposals
Purchase of Advanced Metering Infrastructure (AMI) System
Additional Questions & Responses

1. What level of accuracy does the GPS coordinate that is collected need to be? Standard (10 Meter), <3 Meters, Sub meter or sub foot? **Accuracy should be <3 meters.**
2. Will the City accept a postcard as an alternative to the Pre-Installation door Hanger? Pre installation door hanger distribution is much more costly than a postcard. **Post cards will be acceptable.**
3. How many days in advance do we need to notify the end user? **48 hours in advance.**
4. Do they have an existing AMR system with transmitters mounted TTL? **Some (not all) meters are equipped with transmitting nodes for wand reading.**